



NOTES:

- 1 APPROVED DOUBLE CHECK VALVE ASSEMBLY TO LAY HORIZONTAL WITH GROUND. (VERTICAL IF D.O.H. APPROVED)
- 2 DESIGNED FOR BACK SIPHONAGE AND BACK PRESSURE.
- 3 TEST COCKS TO EITHER FACE OUTWARDS OR UPWARDS FROM ASSEMBLY.
- 4 THOROUGHLY FLUSH LINES PRIOR TO INSTALLATION OF BACKFLOW PREVENTER.
- 5 THE DCVA MAY BE INSTALLED ABOVE OR BELOW GROUND PROVIDED ALL CLEARANCES ARE MET.
- 6 DO NOT INSTALL IN AN AREA SUBJECT TO FLOODING.
- 7 MUST BE ACCESSIBLE.
- 8 MUST BE PROTECTED FROM FREEZING CONDITIONS.
- 9 THE BACKFLOW ASSEMBLY SHALL BE A STATE APPROVED MODEL.
- 10 A PLUMBING PERMIT IS REQUIRED - PLEASE CONTACT CITY OF WILSONVILLE BUILDING DIVISION.
- 11 MUST BE TESTED AFTER INSTALLATION AND YEARLY THEREAFTER BY AN OREGON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER. TEST RESULTS SHALL BE SENT TO THE CITY OF WILSONVILLE PUBLIC WORKS DEPARTMENT.

Standard Double Check Valve Assembly 2" & Smaller

DRAWING NUMBER: B-4000	DRAWN BY: SR	SCALE: N.T.S.
FILE NAME: B-4000.dwg	APPROVED BY: NK	DATE: 03/21/06

CITY OF WILSONVILLE



PUBLIC WORKS STANDARDS