



NOTES:

1. DITCH INLET CONSTRUCTION IN ACCORDANCE WITH ASTM C-478
2. 8" OF COMPACTED 3/4"-0 CRUSHED ROCK BASE MATERIAL REQUIRED..
3. PRIOR APPROVAL REQUIRED FOR DITCH INLET STRUCTURES FOR PIPE SIZES 24" OR LARGER.
4. PRECAST MINIMUM WALL THICKNESS TO BE 5", REINFORCEMENT TO BE REBAR MEETING ASTM A615 GRADE 60 OR WELDED WIRE MEETING ASTM A497.
5. CONCRETE SHALL ATTAIN A MIN. COMPRESSIVE STRENGTH OF 3000 PSI IN 28 DAYS.

Ditch Inlet (Type D)

CITY OF
WILSONVILLE



DRAWING NUMBER: S-2120

DRAWN BY: SR

SCALE: N.T.S.

FILE NAME: S-2120.DWG

APPROVED BY: NK

DATE: 6/4/14

PUBLIC WORKS STANDARDS