

Addendum No. 4
TO WILSONVILLE POLICE/PUBLIC WORKS SRGP
SEIMIC IMPROVEMENT PROJECT
CONTRACT DOCUMENTS, PROJECT PLANS AND SPECIFICATIONS

DATE: March 15, 2019

ADDRESSEE: PLAN HOLDERS

RE: RESPONSE TO REQUEST FOR INFORMATION (RFI)

Prior Addenda: 3

The following Addenda to the Contract Documents, Project Plans and Specifications shall be considered merged with the original bid package as if they were whole. This addendum is a Response to a Request For Information (RFI) that was received AFTER the deadline to submit questions. The City is not required to respond to any RFI received after the official deadline, but has determined that the response, in this instance, would be meaningful for clarification purposes. By responding to this RFI, the City is not bound or obligated to respond to any other RFI that is received after the deadline.

Add the following documents to the Contract Documents, Project Plans and Specifications.

Q1: “Sheet G102 Note 3 states existing concrete landing & stairs to remain, but in order for new footing to be installed along the west side of building excavation limits will be into area where existing concrete is to remain. Please advise on the removal and replacement of existing concrete stairs and landing.”

A1: The pier foot located at grid B-1 rests below the exterior stair landing. Please reference 3/A-301.

Q2: “Sheet G-102 Note 6 existing security fence, can security fence be temporarily removed in the southwest corner to gain access to work area.”

A2: The fence can be temporarily removed and replaced for construction purposes.

Q3: “Sheet AD-201 Note 6 states to demolish existing downspouts, does existing downspout get replaced and reconnected to existing storm line? If so, where does it connect to existing storm line and at what elevation?”

A3: Yes, downspouts to be replaced at areas of seismic improvements. Contractor to connect to existing boot and storm line. Contractor to field verify elevation of existing storm line connect.

Acknowledgement of receipt of this ADDENDUM within the bid submittal is required.